


Action Plan for Reduction of NRW


सचिव
जल कल विभाग
कानपुर

Kanpur Municipal Corporation
March, 2017

Contents

1	Introduction	3
1.1	Measurement of NRW	3
1.2	General theory of loss	4
2	Action Plan to Reduce NRW	6

Action Plan to Reduce Non-Revenue Water (NRW)

– A Concept Note

1 Introduction

The Urban population in India is growing at a rate faster than ever and the services in cities are crumbling to the increasing pressure. Along with other key services of the city, water supply is also struggling to maintain adequacy and quality of services provided to the citizens. Few of the major problem faced by Water Supply sector is the large proportion of water loss in distribution and poor collection of revenue for the supplied water. This situation is common in majority of Indian cities and has led to inefficient performance of water supply services.

To overcome the challenge the city needs to identify the losses and take necessary measures to reduce it. Non-Revenue Water (NRW) is a good indicators to measure the losses and high NRW typically indicate a poorly managed water utility.

Non-revenue water (NRW) is water which is supplied (produced and purchased) but not paid for, including technical losses (leakage), not billed water, illegal connections, poor water meter performance and inaccurate reading and accounting of metered flows. The impacts of NRW are the loss of scarce resources and financial revenue in a cash strapped water sector.

The central government under AMRUT mission has aimed to reduce the NRW in cities, and has included the same as a priority reform.

The extent of NRW in Kanpur city is not accurately measured due to unmetered connection, however it has been estimated approximately 40% i.e. 251.4 MLD. This is unacceptable and for that reason KMC has prepared a Concept Note on Plan of Action to reduce the NRW less than 20% in next 5 years.

1.1 Measurement of NRW


This indicator highlights the extent of water produced which does not earn the utility any revenue. This is computed as the difference between the total water produced (ex-treatment plant) and the total water sold expressed as a percentage of the total water produced.

NRW comprises of:

- a) Unbilled Authorized Consumption:** Consumption which is authorized but not billed, such as public stand posts water used by the utility for operational purposes, water used for firefighting, and water provided for free to certain consumer groups;
- b) Commercial (or apparent) losses:** Apparent losses such as illegal water connections, metering inaccuracies, customer meter under registration, data handling errors and theft of water in various forms;
- c) Physical (or real) losses:** Real losses which are leakages in the transmission and distribution networks from all parts of the system and overflows at the utility's reservoirs. They are caused by poor operations and maintenance, the lack of active leakage control, and poor quality of underground assets.

For the purpose of measurement of NRW following data is required:

Kanpur Municipal Corporation


सचिव
जल कल विभाग
कानपुर

1. **Total water produced and put into the transmission and distribution system (Million Litres per Day): a)**

Daily quantities should be measured through metering, and records on the transmission and Distribution system should be maintained. The total supply for the month should be based on the aggregate of the daily quantum. Only treated water input into the distribution system should be measured. If water is distributed from multiple points, the aggregate of that quantity should be considered. This quantum should include water purchased directly from any other sources and put into the distribution system, if any. Water may have been purchased from neighboring ULBs, Cantonment Boards, etc.

2. **Total water sold (Million Litres per Day): b)**

The actual volume of water supplied to customers who are billed for the water provided. Ideally, this should be the aggregate volume of water consumed as per which consumers have been billed. However, in the absence of a complete and functionally effective metering regimen, alternate methods of measurement need to be evolved, with lower but acceptable levels of reliability.

$$\text{NRW} = \left[\frac{(a - b)}{a} \right] * 100$$

1.2 General theory of loss

The majority of funds for management of water supply system comes through the revenue generated from collection of user charges. Because of a large share of NRW, the revenue generated is very less, thus reducing the scope for improvement in the system. This becomes a vicious circle that does not address the core problem.

Figure 1: Vicious Cycle of NRW



Other Losses

2 Action Plan to Reduce NRW

The key to developing a strategy for management of non-revenue water (NRW) is to gain a better understanding of the reasons for NRW, and the factors which influence its components. Then techniques and procedures can be developed and tailored to the specific characteristics of the network and local influencing factors, to tackle each of the components in order of priority. Causes of failure need to be investigated in depth at the stage of action planning and implementation and a more systematic approach needs to be developed.


Following are the components of NRW

1. leakage
2. Connections
3. Authorized consumption free of charge
4. Discounts
5. Water for Municipal Services
6. Water Metering

Component	Present Status	Action Taken
leakage	The identification of leakage in pipeline is detected via monitoring staff and also by reporting done by public. After the detection of leakage the repairing work is carried out as soon as possible through skilled manpower.	A total 3311 nos. of leakage are been repaired during FY 2016-17
Connections	There are total of 265575 nos. of authorized connections and all are billed on the basis of minimum charges.	Illegal connections are regularized on detection. There were 155 nos. of illegal connections are regularized in FY 2016-17
Authorized consumption free of charge	At present scenario 10 % of total quantity of treated water is supplied for authorized consumption like public utility/services via tankers officially. This kind of consumption is unavoidable	This kind of consumption is unavoidable .
Discounts	Till now only 10% rebate is given to HH connection for timely submission of bill amount	There may be a provision raised for volumetric tariff, it can be only done after full metering is achieved.
Water for Municipal Services	7 % of total treated water is supplied for parks, median spraying etc.	After metering of the connections for municipal services can be reduced.
Water Metering	Till now the status of metering is nil.	Metering is to be done at consumer connections, sources (Raw water, Supplied water), the work of metering is proposed in AMRUT scheme formerly in JnNURM scheme and the implementation work is to be done by U.P. Jal Nigam.

Note:- This action plan can be carried out after the implementation of AMRUT scheme.

Kanpur Municipal Corporation


 सचिव
 जल कल विभाग
 कानपुर